

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 948 | D/SWA | NSA

Dated: 28/01/2024

It is certified that an inspection team headed by AIKA SINGH - CHEMIST(Name of Officers with designation) from KANPUR NAGAR NIGAM(Name of Department/ Office) inspected the ESCORTS WORLD SCHOOL, K-1(Name & Address of the school) on 30/12/2023 (date of inspection) and found that the ESCORTS WORLD SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. Keshavpuram, KanpurThe above is valid for a period of ONE YEARSignature with Seal: M

Name

Aika

Designation

Dr. Amit Singh Gaur
City Health Officer

Name & Address of the Office / Department

नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

To

ESCORTS WORLD SCHOOL
K-1, Keshavpuram, Kanpur

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the	M/S ESCORTS WORLD SCHOOL, K-1, Keshaypu Kanpur
Sample taken from	'Submersible'
Date of sample Drawn	30/12/2023
Date of analysis	30/12/2023
Physical Character	Transparent
P. H. Value	8.39
Free Ammonia Parts per 1000000	Nil
Alouninoid Ammonia Part per 1000000	Nil
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.8
Chloride Part per 1000000	104.00
Nitrates Parts per 1000000	Trace
Nitrates Parts per 1000000	Trace
Total solid part per 100000	1030.00
Fixed solid Parts per 1000000	840.00
Volatils solid Parts per 100000	190.00
Appearance on ignition	No Charring
Total hardness Parts per 1000000	540.00
Permanent hardness Parts per 1000000	480.00
Temporary hardness Parts per 1000000	60.00

K.N.N. PRESS

Remarks :

'Potable'

No. 329/Sw/2024 dated 29/01/2024

Copy forwarded for favour or information to

M/S Escorts World Public School
K-1 Keshaypu Kanpur

Nagar Swasthya Adhikari
Nagar Nigam Kanpur
Nagar Swasthya अधिकारी
नगर निगम कानपुर



KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from Esports World School, K-1, Keshu

Name & designation of the person collecting samples..... Alka Singh - Chemist (Health)

Date & time of collection	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count	Probable on of coliform organism in 100 CC of original water			Free Residual Chlorine part per Million	
		at 37.°c in 48 hours	at room temp- return in 72 hours		Quantity of water put in each tube No of tubes put up	50ML. 1	10 ML. 5		1 MI 5
30/12/2023	Submersible	34	71	—	Nil	1	1	Zero	Nil

Remark:- P.L.C. must be 0.2 PPM - Apply disinfectant

Copy for Information Forwarded to (1) ^{MS} Esports World School

(2) N.S.A. Kanpur Nagar Nigam

ALKA SINGH
(Chemist)
Nagar Nigam Kanpur

D.No. 529 / SSHA / Chan